



BAHOUR COMMUNE PANCHAYAT
BAHOUR, PUDUCHERRY
Phone No.0413-2633438 &2633883
E-Mail: bcp.pon@nic.in



PROFORMA FOR SAFE DRINKING WATER CERTIFICATE

No.81-67/BCP/Engg/JE-III/2022-23/

Bahour, Dt. 29.08.23

It is certificate the bore water in the School premises good for drinking and other purposes for which necessary test report has been obtained from the water testing Lab Public Health Division , PWD, Puducherry and found good. The inspection team headed by S. Mouttousivame, Assistant Engineer from Bahour Commune Panchayat inspected the Maharishi Vidya Mandir on 29.08.2023 and found that the Maharishi Vidya Mandir, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic water supply in the school building & the campus as per norms prescribed by the Central/ State/ U.T.Govt. The above is valid for a period of one year.

Signature with seal

Name

S. Mouttousivame
29/8/23
ASSISTANT ENGINEER
Designation **BAHOUR COMMUNE PANCHAYAT**
BAHOUR, PUDUCHERRY - 607402.

Name & Address of the office / Department

To

The Head Master,
Maharishi Vidya Mandir,
Mullodai, Kanniyakoil,
Puducherry 607 402.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY



Date: 18.08.2023

Report No. : TR/WTL/PHD/PWD/PDY/2023/W-1083
ULR-TC758022000000778F

TEST REPORT- CHEMICAL

Page 1 of 1

Customer Name & Address : The Chairman,
Maharishi Vidya Mandir, Mullodai, Kanniyakoil, Puducherry-607402.
Customer Reference : Letter MVM@PWTLPHD/WQ/2023-24/001 dt: 25.07.2023

SAMPLE DETAILS

Sample Code	: 2023/W-1083	Sampled by	: Customer
Product Category	: Water	Sampled on	: 10.08.2023
Sample Name	: Drinking Water	Sampling Location	: Maharishi Vidya Mandir campus, Mullodai, Kanniyakoil, Puducherry.
Sample Description	: R.O. Water	Sampling Procedure	: --
Identification by Customer	: Sample - 1	Sample Received on	: 10.08.2023
Sample Condition	: Fit for analysis	Test Completed on	: 18.08.2023
Test Started on	: 10.08.2023		

TEST RESULTS

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H ⁺ B	--	6.26	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	365	---	---
Total Dissolved Solids	APHA, 23rd Edition, 2017, 2540 C	mg/L	236	500 Max	2000 Max
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	77.3	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	144	200 Max	600 Max
Calcium as Ca	APHA, 23rd Edition, 2017, 3500-Ca B	mg/L	23.8	75 Max	200 Max
Magnesium as Mg	APHA, 23rd Edition, 2017, 3500-Mg B	mg/L	20.6	30 Max	100 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	0.26	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	48.1	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	17.0	200 Max	400 Max
Nitrate as NO ₃	APHA, 23rd Edition, 2017, 4500-NO ₃ B	mg/L	<1.00	45 Max	No Relaxation
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	0.17	1.0 Max	1.5 Max

.....End of Report.....

Anita Ben
Authorized Signatory
Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No: TR/WTL/PHD/PDY/2023/B-0408

Date:11.08.2023.

TEST REPORT

Customer Name & Address: The Chairman,
Maharishi Vidya Mandir, Mullodai, Kanniyakoil, Puducherry-607402.
Customer Reference: Letter MVM@P/WTLPHD/WQ/2023-24/001 dt: 25.07.2023.

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2023/B-0408	Sampled by	Customer
Sample Name	: Water	Sampled on	09.08.2023
Sample Description	: R.O. Water	Sampling Location	Maharishi Vidya Mandir campus, Mullodai, Kanniyakoil, Puducherry.
Temperature	: --	Sampling Procedure	--
Identificaiton by Customer	: Sample - 1	Sample Received on	09.08.2023
Sample Condition	: Fit for analysis	Test Completed on	11.08.2023
Test Started on	: 09.08.2023		

Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....

A. Anita Ben
Authorized Signatory
A. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERRY

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.