

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Certificate of Structural Soundness for the School

Statement accompanying the Form-A.

- | | | |
|--|---|--|
| 1. Door Number of building | : | M.V.M Kids
Door No.42A |
| 2. Location (Street, Name, Ward Number,
Name of place, i.e.Corporation/Municipality/
Panchayat/Panchayat Union/Township/
Contonment, etc.,) | : | Bodichetty Street
Ward No.4, Block No.10,
T.S. No.491,
Thiruppapuliyur
Cuddalore City Municipal Corporation Limit
Cuddalore Taluk and District. |
| 3. Year of construction | : | Front building : 2002
Back side building : 1990 |
| 4. Approximate cost of construction as
per current rates | : | Rs.30,00,000-
(Rs. Thirty lakhs only) |
| 5. Purpose for which the building is being
used or proposed to be used | : | To run the kids school |
| 6. Purpose for which the building has now
been used | : | -do- |
| 7. Details of construction of the building
(particulars of the foundation soil,
specification of the various parts
under) | : | |
| a) Foundation | : | RCC footings and Conventional spread footings |
| b) Basement | : | Brick masonry with C.M. |
| c) Superstructure | : | Brick masonry with C.M |
| d) Floor and roof, are to be given | : | Mosaic tiles and cement mortar floor finishing
RCC roof and Madras terrace roof |

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore - 607 001 (TN)

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic.Act)
COLLECTERATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
D.No: 3/201, First Cross Street, Friends Nagar,
SEMMANDALAM, CUDDALORE - 607 001.

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

e) Area of the building :	Sq.Ft.	Sq.M.
Ground floor		
RCC Roof area	1709.01	158.83
Madras terrace roof area	899.54	83.60

8. Period for which licence is required : From 01-08-2024 to 31-07-2027

9. Number of persons to be accommodated : 200 Nos (Capacity)

“ Certified that no addition or alteration has been made to the existing (M.V.M Kids, Door No.42A, Bodichetty Street, Ward No.4, Block No.10, T.S. No.491, Thiruppapuliur, Cuddalore City Municipal Corporation Limit, Cuddalore Taluk and District.) building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently.”

Date :

Signature of the owner of the building

Date : 01-08-2024

Signature of the Registered Engineer

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic.Act)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
D.No: 3/201, First Cross Street, Friends Nagar,
SEMMANDALAM, CUDDALORE - 607 001.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore -607 001.(TN)

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96, Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer, Panel Valuer of Banks

Form –B

(Form of Certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act. 1965 (Tamil Nadu Act. 13 of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (licensing) Rules . 1966).

I certify that I have inspected the building of M.V.M Kids, Door No.42A, Bodichetty Street, Ward No.4, Block No.10, T.S. No.491, Thiruppapuliur, Cuddalore City Municipal Corporation Limit, Cuddalore Taluk and District.. mentioned in the statement and furnish below its salient technical features :-

I. Foundation :

- | | | |
|--|---|---|
| 1. Depth below Ground level | : | RCC footings : 1.83 M.
Conventional spread footings : 1.52 M |
| 2. Nature of soil met with at foundation level | : | Sandy gravel |
| 3. Pressure at foundation | : | 4.00 M.Ton/Sq.M. |
| 4. Probable safe bearing capacity of the soil met with at foundation | : | 20.00 M.Ton/Sq.M. |

II. Super structure :

- | | | |
|--|---|--|
| 1. Maximum stress in the most critical section of masonry and concrete | : | 1600 Kg.Sq.Cm. |
| 2. Nature of masonry and concrete and its permissible stress | : | Brick masonry with cement mortor-3000 ksc
and Concrete – 5000 ksc |

The structural soundness of the building has been verified by me with reference to ISI loading standards 878 (Latest version) and other relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from 01-08-2024 to 31-07-2027.

Date : 01-08-2024

Address : 3/201, Ist Cross street, Friends Nagar, Cuddalore - 607 001.

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic.Act)
COLLECTERATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
D.No: 3/201, First Cross Street, Friends Nagar,
SEMMANDALAM, CUDDALORE - 607 001.

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Form – C

Statement to accompany The Certificate of Structural Soundness

- | | | |
|--|---|--|
| 1.Location of the building, door number, street and name of the place | : | M.V.M Kids
Door No.42A
Bodichetty Street
T.S.No.491, Ward No.4
Block No.10,
Thiruppapuliur
Cuddalore City Municipal Corporation Limit
Cuddalore Taluk and District. |
| 2. Age of the building | : | Front building : 22 years
Back side building : 34 years |
| 3. Number of Storeys | : | Single storeyed |
| 4. Short description of structures steel/ Rcc framed or load bearing masonry | : | RCC framed structure
and Load bearing structure |
| 5. Purpose for which the building is certified for use | : | To run the kids school |
| 6. The period for which the building will be structurally sound | : | 3 years (from 01-08-2024 to 31-07-2027) |
| 7. Number of persons to be accommodated | : | 200 Nos (capacity) |
| 8. Remarks | : | Building is Structurally sound ,strong and stable |

Date : 01-08-2024

Er. K.G. MANIVACHAKAM, B.E., M.I.E., F.I.V., C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic.Act)
COLLECTORATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
D.No. 3/201, First Cross Street, Friends Nagar,
SEMMANDALAM, CUDDALORE - 607 001.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore - 607 001.

Er.K.G.MANIVACHAKAM,B.E.,M.I.E.,F.I.V.,

Class IA Registered Engineer, (PANEL REG.No.AEE/T1/B/94630/96,Competent person to release structural soundness Certificate for public buildings, Chartered Engineer (India) IEI(REG.No.M-111304/0), PPE IV- REG.No.F-10285, Reg.No.under section 34AB of Wealth Tax Act – Category I/566 of 2002 – 2003, Approved Valuer/Civil Engineer,Panel Valuer of Banks

Form – E

(Form of report to be made to the competent authority by inspecting authorities or officers appointed under other Act Under Section 28 of the Madras Public Buildings Licensing) Act. 1965 (Madras Act 13 of 1985) referred to in rule 7 of the Madras Public Building Licensing Rules. 1966.

- | | | |
|--|---|---|
| 1.Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law | : | Er.K.G.Manivachakam
B.E.,M.I.E.,F.I.V.,
Registered Engineer Class I.A
3/201,1st Cross Street
Friends Nagar
Cuddalore – 607 001. |
| 2. Location of the building inspected
D.No. Street No. Name of place i.e.
Municipal corporation / Municipality/
Panchayat or Panchayat Union/
Township/Contonment. | : | M.V.M Kids
Door No.42A, Bodichetty Street
Block No.10,
T.S. No.491,Ward No.4
Thiruppapuliur
Cuddalore City Municipal Corporation Limit
Cuddalore Taluk and District |
| 3. Date of Inspection | : | 31-07-2024 |
| 4. Purpose for which the building is used | : | To run the kids school |
| 5. Nature of defects noticed | : | Nil |
| 6. Suggestion of rectifying defects | : | Nil |
| 7. If in a dangerous condition immediate action recommended to be taken | : | Nil |

Date : 01-08-2024

Er. K.G. MANIVACHAKAM, B.E.,M.I.E.,F.I.V.,C.Eng.
CLASS - IA REGISTERED ENGINEER,
(Under Tamil Nadu Public Building Lic.Act)
COLLECTERATE PANEL ENGINEER,
Chartered Engineer, Approved Valuer,
D.No: 3/201, First Cross Street, Friends Nagar,
SEMMANDALAM, CUDDALORE - 607 001.

Address : 3/201, 1st Cross street, Friends Nagar, Cuddalore, 607 001.